

Classification report – Moelven Wood AS

Classification report for roof exposed to external fire

Royal takbord endpløyd brun

NS-EN 13501-5:2016

Author:

Dag Olav Snersrud



3 Classification and field of application

3.1 Reference

This classification has been carried out in accordance with NS-EN 13501-5:2016.

3.2 Classification

The roof *Royal takbord endeployd brun* with square density of 14.95 kg/m² in relation to its external fire performance is classified:

B_{ROOF} (t2)

4 Field of application

This classification is valid for the following conditions:

- **range of pitches:** - all pitches.
- **range of substrates:** - combustible and non-combustible substrates, having a density ≥ 15 kg/m³.

5 Limitations

This document does not represent type approval or certification of the product.